

LINDA LINGLE  
GOVERNOR



BARBARA E. ARASHIRO  
ACTING EXECUTIVE DIRECTOR

**STATE OF HAWAII**  
DEPARTMENT OF HUMAN SERVICES  
HAWAII PUBLIC HOUSING AUTHORITY  
1002 NORTH SCHOOL STREET  
P.O. BOX 17907  
Honolulu, Hawaii 96817

**ADDENDUM NO. 3**

TO THE  
PLANS AND SPECIFICATIONS  
FOR  
FURNISHING LABOR AND MATERIALS  
REQUIRED FOR

**PHYSICAL IMPROVEMENTS  
AT  
KAHEKILI TERRACE**

HA 1-17

2015 HOLOWAI PLACE  
WAILUKU, MAUI, HAWAII

TAX MAP KEY NO: (2) 3-4-33: 23

HPHA JOB NO. 07-064-117-S/F

IFB-CMS-2009-33

February 1, 2010

The items listed hereinafter are hereby made a part of the contract for the above project and shall govern the work, taking precedence over previously issued plans and specifications governing the items mentioned.

A. SPECIFICATIONS

1. TECHNICAL SPECIFICATION

- a. Section 03930 Concrete Rehabilitation – Paragraph 1.06 Warranty, Item B.1, Added Language, "The Surety shall not be held liable beyond two years of the project acceptance date."
- b. Section 08520 Aluminum Framed Awning Windows – Paragraph 1.08 Warranty, Item B, Added Language, "The Surety shall not be held liable beyond two years of the project acceptance date."

B. DRAWINGS

No revisions.

C. SUBMITTALS

1. Substitution Requests

- a. Polyroof in lieu of Siplast PMMA, Kemper Polyester, Soprema PMMA.  
JM60 PVC membrane for Sarnafil (PVC).  
JM FB 115-60 mil TPO Membrane for Firestone (TPO).
  - 1) Rejected – Lack of Performance History in Hawaii.
- b. Fibertite 8540 for Sarnafil G-410.  
Fibertite 8552 for Sarnafil G-410.
  - 1) Rejected – Membrane thickness not equal.

Approved by:



Rick T. Sogawa  
Acting Procurement Officer

